

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419 WWW.QAL.ORG

ELECTRICAL LISTING PROGRAM

Class: Location: Listing No. Report No.	Delta, BC, Canada E11086 E11086-1901 E11086-1901 February 26, 2020							
Standards:	CSA C22.2 No. 273 Cablebus							
Product:	Complete Cablebus System (Termination to Termination) and Associated Fittings Permanently Connected, Ventilated, Class B							
Markings:	 Products are marked in a permanent manner where it is readily visible after installation with the following: a) Manufacturer's name or trademark b) Model designation c) Month and year of manufacture d) Product ratings: voltage, frequency, watts e) QAI file Number: E11086 f) The wording "Conforms to CSA C22.2 No. 273" g) Warning markings as required by the standards in English and French h) QAI Logo 							
Models / Ratings:	Products	Max. Rating		Max. Rating Short-Circuit			Class	Leastier
		Volts	Amperes	Amperes RMS	Duration	Amperes Peak	Class	Location
	Cablebus and associated fittings	46KV	5000A	80KA _{rms}	1 second	200KA _{peak}	В	Wet/Dry

Note:

- 1- The manufacturer / Listee maintains a system to ensure each product complies with this report prior to application of the QAI mark.
 - 2- The product is installed in accordance with the CEC as applicable.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. LOS ANGELES, CA: 909.483.0336 fx. WASHINGTON, DC: 540.636.9445 ph. 540.636.9414 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 416.550.9280 SEATTLE, WA 425.512.8419 WEBSITE: WWW.QAI.ORG

Cautionary Markings:	1.	WARNING! DO NOT USE AS A WALKWAY, LADDER, OR SUPPORT FOR PERSONNEL
		AVERTISSEMENT! NE PAS UTILISER COMME PASSERELLE, ÉCHELLE OU SUPPORT POUR LE PERSONNEL
	2.	WARNING: IF THE CABLEBUS SYSTEM HAS BEEN EXPOSED TO A SHORT CIRCUIT SEE THE MANUFACTURERS INSTALLATION MANUAL FOR MAINTENANCE PROCEDURES BEFORE RE- ENERGIZING.
		AVERTISSEMENT : SI LE RÉSEAU DE CONDUITS DE CABLES A ÉTÉ EXPOSÉ À UN COURT-CIRCUIT, CONSULTER LE MANUEL D'INSTALLATION DU MANUFACTURIER POUR OBTENIR LA PROCÉDURE À SUIVRE AVANT DE REMETTRE SOUS TENSION.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.
