

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA OK: TORONTO, ON SEATTLE, WA WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419

WWW.OAI.ORG

## **ELECTRICAL LISTING PROGRAM**

Customer: Superior Tray Systems Inc.

Class: Cable Bus

Location: Delta, BC, Canada

Listing No. E11086

Report No. E11086-1901 Project No. E11086-1901

Effective Date: February 14, 2020 Last Revised Date: February 14, 2020

Expires: N/A

Standards: CSA C22.2 No. 273 Cablebus

Product: Cable Bus and Associated Fittings

Dry Locations use, Permanently Connected, Ventilated, Class B.

Products are marked in a permanent manner where it is readily visible after Markings:

installation with the following:

a) Manufacturer's name or trademark

b) Model designation

c) Month and year of manufacture

d) Product ratings: voltage, frequency, watts

e) QAI file Number: E11086

The wording "Conforms to CSA C22.2 No. 273"

g) Warning markings as required by the standards in English and

French

h) QAI Logo . UH

## Models / Ratings:

Products	Max. Rating		Max. Rating Short-Circuit				
	Volts	Amperes	Amperes RMS	Duration	Amperes Peak	Class	Location
Cable Bus and Associates Fittings	15KV	5000A	80KA <sub>rms</sub>	1 second	200KA <sub>peak</sub>	В	Dry Locations

Note:

- 1- The manufacturer / Listee maintains a system to ensure each product complies with this report prior to application of the QAI mark.
- 2- The product is installed in accordance with the CEC as applicable.



VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419

WWW.QAI.ORG

Cautionary Markings:

WARNING! DO NOT USE AS A WALKWAY, LADDER, OR SUPPORT FOR PERSONNEL
AVERTISSEMENT! NE PAS UTILISER COMME PASSERELLE, ÉCHELLE OU SUPPORT POUR LE PERSONNEL
WARNING: IF THE CABLEBUS SYSTEM HAS BEEN EXPOSED TO A SHORT CIRCUIT SEE THE MANUFACTURERS INSTALLATION MANUAL FOR MAINTENANCE PROCEDURES BEFORE REENERGIZING.
AVERTISSEMENT: SI LE RÉSEAU DE CONDUITS DE CABLES A ÉTÉ EXPOSÉ À UN COURT-CIRCUIT, CONSULTER LE MANUEL D'INSTALLATION DU MANUFACTURIER POUR OBTENIR LA

PROCÉDURE À SUIVRE AVANT DE REMETTRE SOUS TENSION.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <a href="www.qai.org">www.qai.org</a> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <a href="mailto:info@qai.org">info@qai.org</a>. Please include the listing number in the request.

\*\*