

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE:

877.461.8378 ph.	Ī.	604.527.8368 fx.
909.483.0250 ph.	Ĺ	909.483.0336 fx.
540.636.9445 ph.	İ	540.636.9414 fx.
918.437.8333 ph.	Ĺ	918.437.8487 fx.
416.550.9280		
WWW.QAI.ORG		

that

## FIRE DOOR LISTING PROGRAM

Class: Location:	stomer: Taylor Brothers Doorlock, LLC Class: Fire-Resistant Door Hardware Component ocation: Mount Morris, MI /ebsite: <u>https://nightlock.com</u>			
Listing No. Project No.	F465-1 F465-1 Edition 1			
Effective Date: Last Revised Date:				
Standards:	UL 10B UL 10C NFPA 252 CAN/ULC S104	Fire Tests of Door Assemblies Positive Pressure Fire Tests of Door Assemblies Standard Methods of Fire Tests of Door Assemblies Standard Method for Fire Tests of Door Assemblies		
Product:	<i>NightLock</i> ® <i>Lockdown 1</i> and <i>NightLock</i> ® <i>Lockdown 2</i> Fire-Resistant Door Hardware for use with Neutral & Positive Pressure Rated Category "A" and "B" Fire-Resistant Doors.			
Markings:	<ul> <li>Each produced unit is marked with the following content on a permanent label th is readily visible after installation:</li> <li>Company Name</li> <li>QAI Certified Component logo with 'c' and 'us' indicdators</li> <li>QAI Listing File Number (F465)</li> </ul>			

- The wording "listed Hardware Fire Rating 20-90 Minutes"
- Applicable standards: UL 10B, UL 10C, NFPA 252 and CAN/ULC S104

Models:	Product Name	Door Skin Type	Door Core Type	Maximum Fire-resistance Rating
	NightLock® Lockdown 1	Wood	Solid Wood / Composite	
	NightLock® Lockdown 2	or Steel	Hollow Metal	20 – 90 Minute
			Steel Stiffened	

Notes: The listing noted pertains to NightLock® Lockdown 1 / NightLock® Lockdown 2 products intended for use with appropriately listed and rated door products in fire-resistance rated applications. Where openings have additional criteria beyond the scope of fire-resistance rating, the Authority Having Jurisdiction (AHJ) should be consulted for approval of NightLock® Lockdown 1 / NightLock® Lockdown 2 products used as lock down devices.

*Product is to be installed in accordance with the manufacturer's installation instructions.* 



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 416.550.9280 WEBSITE: WWW.QAI.ORG

Refer to the <u>FD002 - Fire Door Guidelines</u> for general guidelines of fire door assemblies.

The materials, products or systems listed herein have been qualified to bear the QAI Listin Mark under the conditions stated with each Listing. Only those products bearing the QAI Listin Mark are considered to be listed by QAI. No warrantee is expressed or implied, and n guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Vis the QAI Online Listing Directory located at <a href="https://www.gai.org">www.gai.org</a> for the most up to date version of thi Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.

\*\*\*