

VANCOUVER, BC: LOS ANGELES, CA: 909.483.0250 ph. 905.605.5444 ph. TORONTO, ON: 918.437.8333 ph. | TULSA, OK: MIAMI, FL: 305.885.3328 ph. | WEBSITE: WWW.QAI.ORG

877.461.8378 ph. | 604.527.8368 fx. 909.483.0336 fx. 918.437.8487 fx. 305.885.3329 fx.

# FIRE DOOR FRAME LISTING PROGRAM

Customer: Western Door Manufacturing Ltd. Class: Fire Door Frames Location: Surrey, BC

Listing No. F456-2 Project No. F456-2 Edition 2

Effective Date: July 9, 2020 Last Revised Date: October 10, 2023

> Standard Method for Fire Tests of Door Assemblies Standards: CAN/ULC-S104 UL 10B Standard for Fire Tests of Door Assemblies

**Product:** 20 Minute Fire-Resistance Rated Fire Door Frames

Markings: See FD001 - Fire Door Labeling requirements

## Models: 20-MINUTE CATEGORY C WOOD FIRE DOOR FRAMES

### Maximum Sizes:

Swing Type:	Maximum Dimensions	
	Width:	Height:
Single Swing	3'6" (1067 mm)	8'0" (2438 mm)
Pairs / Double Egress	Not Permitted	

### LIMITATIONS:

Minimum Frame Depth: Maximum Frame Depth:	4-9/16" (116 mm) Equivalent to wall thickness	
Minimum Frame Leg Thickness:	1-1/4"	(32 mm)
Minimum Rabbet for Door:	1-3/4" [-1/16"]	(44 mm [-1.6 mm])
Minimum Stop Height:	5/8"	(16 mm)
Minimum Stop Width:	2-7/8"	(62 mm)
Veneer:	2.5 mm or greater	

Hardwood Facings: Permitted.

**Electric Raceway:** Not permitted.

**Door Closers:** Surface mounted: Permitted. Mortised: Not permitted.

Plant-Ons: Permitted.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. TORONTO, ON: 905.605.5444 ph. | TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. MIAMI, FL: 305.885.3328 ph. | 305.885.3329 fx. WEBSITE: WWW.QAI.ORG

#### Installation:

- Fastened through the frame legs with #8 x 3" (76 mm) length screws spaced at 24" (610 mm) on center around frame.
- Hinge and latch locations each use two #12 x 3-1/2" (89 mm) screws that pass through the frame and into the wall framing.
- Gaps are required to be sealed with silicone sealant prior to placement of casing.
- Casing to be anchored with finishing nails at minimum 18" on center spacing.
- **Notes:** Refer to QAI evaluation report F456-2 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the <u>QAI FD002</u> - Fire Door Guidelines for general guidelines of fire door <u>assemblies</u>

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

**Note:** The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guaranty is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.

\*\*\*