

VANCOUVER, BC: LOS ANGELES, CA: TULSA, OK: TORONTO, ON WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 918.437.8333 ph. | 918.437.8487 fx. 905.605.5444 WWW.OALORG

PLUMBING PRODUCTS LISTING PROGRAM

Customer: HeatLink Group Inc. Class: Plastic Piping and Accessories Location: Calgary, Alberta Website: www.pexcor.com

Listing No.	P371-1
Effective Date:	November 16, 2020
Last Revised	September 16, 2021
Date:	
Expires:	<n a=""></n>

Standards: ASTM E84 "Standard Test Method for Surface Burning Characteristics of Building Materials".

CAN/ULC S102.2 "Standard Method of test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies".

Product: PureLink Plus (potable) & HeatLink (radiant) pipes with fittings in the following options:

PureLink[™] Plus (potable), (natural, red, white, and blue colors). HeatLink[™] (radiant), (natural colors). HeatLink[™] couplings, fittings and endcaps.

- Markings: All PEX tubing, connectors, fittings, and other accessories (if sufficient space available) shall be permanently marked with the following content applied to an area that is readily visible after installation:
 - a) Manufacturer's name or trademark
 - b) Model designation
 - c) Nominal Pipe Size
 - d) Manufacturer's traceability code.
 - e) QAI file Number: P371
 - f) ASTM E84 / CAN/ULC S102.2 Ratings (FSI ≤ 25 / SDI ≤ 50)
 - g) QAI logo shown here:



Products for use in Canada may require English and French labeling.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 905.605.5444 WEBSITE: WWW.QAI.ORG

<u>Rating(s)</u>: The following outlines the performance of PureLink PlusTM and HeatLinkTM products in accordance with the noted standards.

ASTM E84 – Surface Burning Characteristics

Products	Limitations	Flame Spread Index	Smoke Developed
		(FSI)	Index (SDI)
PureLink™ (red, white, blue, natural¹)	Up to 2 inch (51 mm) nominal diameter pipes and accessories installed with ½-inch (13 mm) pipe insulation ² ; no spacing requirements between adjacent runs of tubing.	≤ 25	≤ 50
PureLink™ (natural)	 2 inch (51 mm) nominal diameter pipe supported continuously with 20-gauge pipe supports covering minimum half exposed pipe area. PureLink™ exposed between pipe supports requires encasing with ½ inch (13 mm) approved pipe insulations². Piping is to be clamped with standard support clamps following HeatLink Group, Inc's installation instructions. 	≤ 25	≤ 50
HeatLink™ (natural)	Up to 1-1/2 inch (38 mm) nominal diameter pipe and accessories installed with rated ½ inch (13 mm) pipe insulation ² ; no spacing requirements between adjacent runs of tubing.	≤ 25	≤ 50

Note 1: Different sizes corresponding to different colors of PureLink[™] and HeatLink[™] are dependent on manufacturers availability. Note 2: List of approved pipe insulation for use with PureLink[™] and HeatLink[™] products are outlined below.



877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 918.437.8333 ph. | 918.437.8487 fx.

Products	Limitations	Flame	Smoke
		Spread Index (FSI)	Developed Index (SDI)
PureLink™ (red, white, blue, natural¹)	Up to 2 inch (51 mm) nominal diameter tubing product and accessories installed with rated ½ inch (13 mm) pipe insulation ² ; no spacing requirements between adjacent runs of tubing.	≤ 25	≤ 50
PureLink™ (natural, red, white, blue¹)	Up to 2 inch (51 mm) nominal diameter piping for water filled pipe. There are no spacing requirements between adjacent runs of this pipe assembly. Optional: Pipe insulation can be installed maintaining the ratings noted ² .	≤ 25	≤ 50
HeatLink™ (natural)	Up to 1-1/2 inch (38 mm) nominal diameter pipe and accessories installed with rated ½ inch (13 mm) pipe insulation ² ; no spacing requirements between adjacent runs of tubing.	≤ 25	≤ 50

Note 1: Different sizes corresponding to different colors of PureLink[™] and HeatLink[™] are dependent on manufacturers availability. Note 2: List of approved pipe insulation for use with PureLink[™] and HeatLink[™] products are outlined below.

The following list of insulation types (at minimum thickness of 1/2 inch (13 mm) are approved for use with HeatLink Group, Inc.'s piping and accessories products at the maximum sizes outlined in the tables above.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 905.605.5444 WEBSITE: WWW.QAI.ORG

The insulations noted must be listed to ASTM C547 by an approved agency are approved for use at the dimension specified above.

Insulation	Flame Spread Index (FSI)	Smoke Developed Index (SDI)
Mason Alley-K Johns Manville Micro-Lok HP Johns Manville Micro-Lok Owens Corning Vapor Wick Owens Corning Fiberglass GLT Pipe and Tank Knauf Earthwool Redi-Klad	≤ 25	≤ 50

Notes: These products are subjected to limitations as specified above and must be installed in accordance with the manufacturers' instructions. Authorities having jurisdiction should be consulted regarding allowable applications. See manufacturer's listings for other standards listed under QAI certification programs.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.
