VANCOUVER, BC: LOS ANGELES, CA: TORONTO, ON: TULSA, OK: MIAMI. FL: WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 905.605.5444 ph. 918.437.8333 ph. |

WWW.QAI.ORG

909.483.0336 fx. 918.437.8487 fx. 305.885.3328 ph. | 305.885.3329 fx.

# FIRE DOOR LISTING PROGRAM

Customer: Amex Doors & Mouldings Ltd. Class: Fire Rated Doors and Frames Locations: Surrey, British Columbia Website: www.amexdoors.com

Listing No. F472

Projects No. F472-1 Edition 1 F472-2 Edition 1

Effective Date: November 25, 2020 Last Revised Date: November 25, 2020

> Standards: UL 10B Fire Tests of Door Assemblies

> > CAN/ULC S104 Standard Method for Fire Tests of Door Assemblies

20 Minute Rated Category "B" Fire Doors with Hose Stream Product:

"Lynden 20 Min Profiled Particleboard Core Fire Door"

Markings: See FD001 - Fire Door Labeling requirements

Models: 20 MINUTE ROUTED WOOD CORE FIRE DOORS CATEGORY B:

#### Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel	Latching:
	Width:	Height:	Type:	Latering.
Single Swing	3'0" (914 mm)	8'0" (2438 mm)	Routed	Single Point (Mortised or Cylindrical) (Concealed or Surface Mounted Fire Exit Devices)
	3'6" (1067 mm)	7'0" (2134 mm)		
Standard Pairs	6'0" (1829 mm)	7'0" (2134 mm)	Routed	3 or 4 Point (Mortised or Cylindrical) (Surface Mounted Fire Exit Devices and/or Vertical Rod)
Double Egress	NOT PERMITTED			

The above Category B Fire Doors are required to be installed with Category G or Category H gasket for use in neutral pressure applications. Category G gasket is to be approved and listed for use with wood door types.

Additions / Limitations: (Review Machining Specifications Report for details)



VANCOUVER, BC: LOS ANGELES, CA: TORONTO, ON: TULSA, OK: MIAMI. FL: WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 905.605.5444 ph. 918.437.8333 ph. | 918.437.8487 fx.

WWW.QAI.ORG

305.885.3328 ph. | 305.885.3329 fx.

**Latch Sets** (Listed and labeled for rated opening and wood door type)

- Cylindrical Latches.
- Mortised Latches.

**Deadbolts** (Listed and labeled for rated opening and wood door type)

- Cylindrical Deadbolts.
- Minimum 5" between hardware cutouts.

Flush / Surface Bolts (Listed and labeled for rated opening and wood door type)

- Surface Mounted Bolts only.
- Mortised Flush-bolts not permitted.

**Hinges** (Listed and labeled for rated opening and wood door type)

Hinges as per NFPA 80.

Fire Exit Devices (Listed and labeled for rated opening and wood door type)

- Surface Mounted Fire Exit Devices and Vertical Rod.
- Concealed Vertical Rods not permitted.

**Door Closers** (Listed and labeled for rated opening and wood door type)

Surface Mounted only.

#### **Surface Mounted Protection Plates**

Steel, brass, bronze, aluminum, listed polycarbonate or listed laminate maximum 16" high.

**Louvers** (Listed and labeled for rated opening and wood door type)

- Square louvers up to 24", installed in full door thickness (away from routed panel)
- Must be installed below latch level.

#### **Metal Edges**

Required use of metal edges and astragal combination for Standard Pairs.

**Viewers** (Listed and labeled for rated opening and wood door type)

Maximum size of 1" diameter, minimum 5" between viewers.

Glass Lites (Listed and labeled for rated opening and wood door type)

- Glazing material shall be listed and labeled for rated opening, lite kit and wood door type.
- Glazing installed in accordance with NFPA 80, and the listed lite kit frame installation instructions.
- Must be installed in full door thickness (away from routed panel).
- Minimum 5" between lite and edge of door or hardware cutout.
- Maximum Area: 1296 sq. in.

**Door Bottoms Seals** (Listed and labeled for rated opening and wood door type)

- Surface mounted and mortised automatic door bottom units.
- Bottom Rail must be doubled.

## **Electric Raceway**

3/8" x 3/8" maximum, at least 2" away from routed panel.



VANCOUVER, BC: LOS ANGELES, CA: TORONTO, ON: TULSA, OK: MIAMI. FL: WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 905.605.5444 ph. 918.437.8333 ph. | 305.885.3328 ph. | 305.885.3329 fx.

WWW.QAI.ORG

909.483.0336 fx. 918.437.8487 fx.

## Electric Strikes, Magnetic Switches and Electrical Power Transfers (EPT)

Not Permitted.

## **Moldings / Plant-Ons**

Not Permitted.

Notes:

Refer to QAI evaluation reports F472-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

Note: The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@gai.org. Please include the listing number in the request.