

## BUILDING PRODUCTS LISTING PROGRAM

Customer: Linear Interior Systems  
 Class: Fire Doors  
 Location: Concord, Ontario  
 Website: <https://www.linearinteriorsystems.com/>

Listing No. F467-1-20  
 Project No. F467-1 Edition 2

Effective Date: September 30, 2021  
 Last Revised Date: June 2, 2026  
 Expires: N/A

Standards: CAN/ULC-S104 UL 10(b) UL 10(c) NFPA 252	<i>Standard Method for Fire Tests of Door Assemblies. Fire Tests of Doors Assemblies. Fire Tests of Doors Assemblies. Standard Methods of Fire Tests of Door Assemblies.</i>
---	--

Product: 20 min Rated Fire Doors

Labels: See [FD001 - Fire Door Labeling requirements](#)

### Minimum 44 mm (1-3/4") Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
<b>Single Swing</b>	912 mm (3'0")	2200 mm (7'1/4")	Flush	Single Point (Mortised or Cylindrical)

Limitations: (Review Machining Report for further detail)

- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
  - [Max. mortise pocket 98 mm (3-7/8") deep x 165 mm (6-1/2") high x 25.4 mm (1") thick]
- Deadbolts (Listed and Labelled)
- Hinges (Listed and Labelled)
  - Hinges as per NFPA 80
- Edge Seal (Category G)
- Fire Exit Devices
  - Surface mounted vertical rod touch bar exit devices
- Surface Mounted door closer (Listed and Labelled)
- Surface Mounted Protections Plates.
  - Max. 12 in. high.
- Viewers
  - Max. size of 1 in. diameter.
- Plant-Ons
  - See machining spec. for details.
- Surface Mounted and concealed door bottom (Listed and Labelled)
  - Max mortise 30 mm (1-3/16") deep by 14 mm (9/16") wide by full width of the door

Notes: *Refer to QAI evaluation report F467-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

*Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)*

*Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).*

*Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.*

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*