

## FIRE DOOR & FRAME LISTING PROGRAM

**Customer:** Lexington Manufacturing, LLC  
**Class:** Fire Rated Doors  
**Locations:** Brainerd, MN  
**Website:** [www.Lexingtonmfg.com](http://www.Lexingtonmfg.com)

**Listing No.** F483

**Effective Date:** June 7, 2023  
**Last Revised Date:** June 7, 2023

**Standards:** UL 10B *Fire Tests of Door Assemblies*  
 UL 10C *Positive Pressure Fire Tests of Door Assemblies*  
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies*  
 CAN/ULC-S104 *Standard Method for Fire Tests of Door Assemblies*

**Product:** 20-Minute Rated Category “A” and “B” Fire Doors

**Markings:** See [FD001 - Fire Door Labeling requirements](#)

**Models / Ratings:** Fire-Resistance Rated Doors

Spec. Owner	Fire Rating	Category	Listing #	Description
<b>Lexington Manufacturing</b>	20-Minute	A / B	F483-1-20	Lexington SR Core 20 Laminated Wood Stile/Rail Panel Type Fire Doors

**Notes:** Refer to QAI evaluation reports F483-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

*Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).*

*Product is to be installed in accordance with the manufacturer’s published installation instructions by qualified installing personnel.*

**Note:** The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing



# LABORATORIES

CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.  
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.  
TORONTO, ON: 905.605.5444 ph. |  
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.  
MIAMI, FL: 305.885.3328 ph. | 305.885.3329 fx.  
WEBSITE: [WWW.QAI.ORG](http://WWW.QAI.ORG)

Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*