

FIRE DOOR LISTING PROGRAM

Customer: Wolman Wood and Fire Protection GmbH
 Class: Fire Doors
 Location: Sinzheim, Germany
 Website: <https://www.wolman.biz>

Listing No. F411-1
 Project No. F411-1 Edition 10

Effective Date: October 12, 2012
 Last Revised Date: December 15, 2023

Standards: CAN/ULC S104 UL 10B UL 10C NFPA 252 ASTM E90	<i>Standard Method for Fire Tests of Door Assemblies. Fire Tests of Doors Assemblies. Fire Tests of Doors Assemblies. Standard Methods of Fire Tests of Door Assemblies. Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements</i>
ASTM E1425	<i>Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements</i>

Product: 20-minute Rated Positive Pressure Fire Doors

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: **20-MINUTE LAMINATED CORE AND WOOD CORE PANEL AND FLUSH DOORS:**

Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	4'0" (1219 mm)	7'0" (2134 mm)	Flat or Raised	Single Point (Mortised or Cylindrical)
	3'6" (1067 mm)	9'0" (2743 mm)		
	4'0" (1219 mm)	8'0" (2438 mm)		
Arched Top Single Swing	3'6" (1067 mm)	9'0" (2743 mm)	Flat or Raised	
Pairs	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	3 or 4 point (Active: Mortised or Cylindrical) (Inactive: Mortised (Manual or Automatic) and Surface Mounted Bolts)
	8'0" (2438 mm)	7'0" (2134 mm)		
	8'0" (2438 mm)	8'0" (2438 mm)		
Double Egress	8'0" (2438 mm)	8'0" (2438 mm)	Flat or Raised	4 point (Concealed or Surface Mounted)



Minimum 1-3/8" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	3'0" (941 mm)	7'0" (2134 mm)	Flush only	Single Point (Mortised or Cylindrical)
Pairs	Not Permitted			
Double Egress	Not Permitted			

*All door assemblies are certified for Shallow Arch door construction

Minimum 2 1/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Double Egress	8'0" (2438 mm)	10'0" (3048 mm)	Flat or Raised	4 Point

Single Point Latching – Cylindrical or Mortise latches and deadbolts, or rim type fire exit hardware for single swing doors, or active leaf of pairs when permitted.

Two Point Latching – Surface mount or concealed vertical rod exit devices for single swing doors. Concealed vertical rod exit devices requires special door construction and is acceptable per the manufacturing specifications.

Three Point Latching – Single point latch for active leaf of standard pairs, Surface mounted manual, or Mortise type or manual or automatic flush bolts, or surface mount or concealed vertical rod exit devices for inactive leaf of pairs.

Four Point Latching - Surface mount or concealed vertical rod exit devices for both leaves of pairs. Concealed vertical rod exit devices require special door construction and is acceptable per the manufacturing specifications.

CATEGORY "A" AND "B" DOORS

Category "A" Doors contain intumescent in the door vertical edges and header. Category "B" doors and doors conforming to CAN/ULC S 104 do not require the door edge intumescent for single swing door applications, intumescent is optional. For doors swinging in pairs, intumescent is required at the meeting edges only.

WITH OR WITHOUT HOSE STREAM

This specification provides a construction for "without hose stream" applications. The hose stream test is required for CAN/ULC S 104 (Canada) but optional for UL 10B, UL 10C and NFPA 252 (USA)

COMPONENTS LIMITATIONS: (Review Machining Report for further detail)

Latch Sets (Listed and labeled for use in 20 minute wood doors, including UL 10C)

- Cylindrical Latches
 - Maximum 2-1/8" diameter bore
 - Maximum 2-3/4" backset
 - Minimum 1/2" throw
- Mortised Latch



- Minimum stile width 5"
- For stile width from 4" to 5"
 - Mortised with the sides and the back of the pocket lined with Interdens Type 15.
 - Maximum mortise pocket dimensions: 15/16" x 6-1/2" x 4-1/2" (W x H x D).

Deadbolts (Listed and labeled for use in 20 minute rated wood doors, and UL 10C)

- Maximum 2-1/8" diameter bore, (cylindrical)
- Maximum 2-3/4" backset, (cylindrical)
- Located a minimum of 3-1/2" center-line to center-line above the latch set
 - Interconnected Deadbolts are allowed
- Mortised Deadbolt – see Mortised Latch Set section above

Hinges (Listed and labeled for use in wood doors, and UL10C)

- Hinges as per NFPA 80, Table 6.4.3.1
- Listed steel butt ball bearing type spring hinges
- SOSS, Tectus concealed hinges Listed for use in 20 minute rated wood doors are permitted.

Fire Exit Devices (Listed and labeled for use in 20 minute rated wood doors and UL 10C)

- Surface Mounted Vertical Rod Fire Exit Device
- Concealed Vertical Rod Fire Exit Device
- Rim Type Fire Exit Devices
- Through-bolts are optional unless required by hardware installation instructions.

Door Closers (Listed and labeled for rated opening)

- Surface Mounted Door Closers are required to be mounted with through-bolts
- Concealed Door Closers in the door and frame header

Door Veneers and Inlays (Optional)

Flush Doors:

- Plastic Laminate (up to 1/16" thick).
- Wood Veneer (up to 1/16" thick).
- Metal Foil (up to 1/16" thick).
- Paper Finish (up to 1/16" thick).
- Fiberglass Reinforced Polymer (FRP) (up to 1/16" thick).
- Vinyl (up to 1/16" thick).
- Lead (up to 1/32" thick).

Recessed Panel Doors:

- Plastic Laminate (up to 1/16" thick).
- Wood Veneer (up to 1/16" thick).
- Metal Foil (up to 1/16" thick).
- Paper Finish (up to 1/16" thick).
- Glass Mirror (up to 1/4" thick).

Face Grooves



- Permitted for flush doors.

Surface Mounted Protection Plates

- Permitted, no limitations, fastened with adhesives or screws.

Louvers

- Listed Louvers permitted, installed in lower area of door, below latch level.

Metal Edges/Astragals (Listed and labeled for rated opening)

- Metal edges and Z-Astragal set for meeting edges of pairs, Optional.

Viewers (Listed and labeled for use in wood doors, and UL 10C)

- Maximum size of 1" diameter
- Multiple viewers located a minimum of 12" on center
- Viewers located a minimum 5-1/2" away from edges of doors.
- Viewers shall be installed in 1 3/4" thick mid rail or panel section unless otherwise listed for wood doors.

Electric Raceway

- Allowed (Refer to F411-20-1-MFG Specification for door construction to accommodate raceway)

Electric Power Transfer (EPT) (Listed for use in 20 minute rated wood doors and UL 10C)

- Securitron Concealed Electrical Power Transfer.
- Mortised with the sides of the pocket lined with Interdens Type 15.
- Maximum mortise pocket dimensions: 1-1/4" x 7-3/4" x 1-5/8" (W x H x D).

Flush Bolts (Listed and labeled for rated opening)

- Mortise manual flush bolts
- Mortise automatic flush bolts. Cutout dimensions limited to 1" wide x 8-1/2" long x 2" deep.
- Flush bolt extensions permitted

Concealed Closer

- Perkomatic door edge closer install at or below latch level.
- Top of Door concealed closer

Concealed Vertical Rod Hardware

- Requires special door construction per manufacturing specifications (Refer to F411-20-1-MFG Specification for door construction to accommodate concealed vertical rod)

Glass Lights (Listed and labeled for rated opening)

- Glazing material shall be listed and labeled for rated opening, light kit and door type
- Glazing installed in accordance with NFPA 80, and the listed light kit frame installation instructions.
- Maximum 1296 sq. in. area with Listed Steel Lite Kit (Max Dimension of 54")
 - For all Wolman – 20 minute doors
- Maximum 2656 sq. in. area (Maximum Dimension of 83")
 - For Wolman – Stile & Rail Doors with Structural Composite Lumber (SCL) Stiles and Rails



- Maximum 9/16" x 9/16" Square wood stops made MDF or solid wood with specific gravity ≥ 0.44 @ 12% m.c. (Stops can be made of any profile that fits within the 9/16" x 9/16" square stop)
 - Single layer of Wolman Palusol 100 encapsulated with PVC (Between the stop and the glass)
- Maximum 1296 sq. in. with Listed Wolman\ proprietary steel channel lite kit using Listed ceramic or wired glazing

Plant-Ons

- MDF or solid wood, plant-on moldings may be applied to one or both sides of a door
- Adhesive and/or mechanical fasteners with a maximum penetration of 3/4"
- Moulding may not be applied closer than 3-1/2" to edge of door, edge of light or edge of hardware cutout

Door Bottoms or Seals (Listed for use in 20 minute rated wood doors)

- Surface Mounted Snap-In in dual durometer vinyl with bulb and fins or with all fins.
- Semi-mortised, or full-mortised bottom seals may be used
- Cutout dimensions are restricted to 1" wide and 1-3/4" deep x full width of the door.

Surface Mounted Hardware (Listed and labeled for use in 20 minute rated wood doors)

- Permitted

Sound Transmission Classification (STC) Ratings for 20 minutes Rated Doors

Ratings below are based on testing a 3'0 by 7'0 door installed in a Wolman composite wood frame, using (3) 4 1/2" X 4" hinges and a single point cylindrical latch. Both flush door and single flat panel recessed panel doors were tested. Ratings will vary for differing sizes and panel design or hardware configurations. The sealed rating is based on the gap around the door sealed with putty, while the operable rating is a fully operational door with seals installed. All of the threshold, weatherstrip and seal products were supplied by Legacy Manufacturing, Bronx, NY.

A. Flush Door, 1 3/4" thick, SCL core stiles and rails, solid MDF panel.

STC Ratings		
Sealed	Operable	Seals/Weatherstrip Components Required
35	33	Threshold – 3665 Series Auto Door Bottom – 7763 (surface applied) Head and Jamb seals applied to frame stop - 7663
35	34	Above Components plus finned gasket installed in door rabbet - 505175 Bk

B. Recessed Single Panel Door, 1 3/4" thick, MDF stiles and rails, HDF + SW 20-1 1/2" thick panel.

STC Ratings		
Sealed	Operable	Seals/Weatherstrip Components Required
33	30	Threshold – 3665 Series Auto Door Bottom – 7763 (surface applied) Finned gasket installed in door rabbet - 505175 Bk

Notes: *Refer to QAI evaluation report F411-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
