

## FIRE DOOR LISTING PROGRAM

**Customer:** Dimension Plywood Inc.  
**Class:** Fire Resistance Rated Doors and Frames  
**Location:** New Albany, Indiana  
**Website:** <http://dimensionplywood.com/>

**Listing No.** F488  
**Projects No.** F488 Edition 1

**Effective Date:** November 1, 2023  
**Last Revised Date:** November 1, 2023  
**Expires:** N/A

**Standards:** UL 10B *Fire Tests of Door Assemblies*  
 UL 10C *Positive Pressure Fire Tests of Door Assemblies*  
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies*  
 CAN/ULC S104 *Standard Method for Fire Tests of Door Assemblies*

**Product:** 20-to-90-minute Neutral & Positive Pressure Rated Category “A” Wood and Composite Fire Doors and Category “C” Fire Door Frames with and without Hose Stream.

**Markings:** See [FD001 - Fire Door Labeling requirements](#)

**Models / Ratings:** **Fire Resistance Rated Doors**

Spec. Owner	Fire Rating	Category	Listing #	Description
<b>Wolman</b>	20 minutes	A	F411-1-1-20	Wood / Composite Core
<b>Wolman</b>	45 minutes	A	F411-1-1-45	Composite Core
<b>Wolman</b>	60 minutes	A	F411-1-1-60	Composite Core
<b>Wolman</b>	90 minutes	A	F411-1-1-90	Composite Core

**Fire Resistance Rated Door Frames**

Spec Owner	Fire Rating	Category	Listing #	Description
<b>Wolman</b>	20 minutes	C	F411-2-20	Composite Frame
<b>Wolman</b>	45 minutes	C	F411-2-45	Composite Frame
<b>Wolman</b>	60 minutes	C	F411-2-60	Composite Frame
<b>Wolman</b>	90 minutes	C	F411-2-90	Composite Frame

**Notes:**

- Refer to QAI evaluation reports F489 and the applicable test reports for test assembly configurations used for fire endurance testing.
- Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)
- Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

- *Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.*

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*