

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE:

877.461.8378 ph.	604.527.8368 fx.
909.483.0250 ph.	909.483.0336 fx.
540.636.9445 ph.	540.636.9414 fx
918.437.8333 ph.	918.437.8487 fx.
416.550.9280	
WWW.QAI.ORG	

## FIRE DOOR LISTING PROGRAM

Class:	33 Lock Inc. Fire-Resistant Doo North Vancouver,	
Listing No. Project No.	F493-1 F493-1 Edition 1	
	February 29,2024 February 29, 2024	L
Standards:	CAN/ULC S104 UL 10B UL 10C NFPA 252	Standard Method for Fire Tests of Door Assemblies Fire Tests of Door Assemblies Positive Pressure Fire Tests of Door Assemblies Standard Methods of Fire Tests of Door Assemblies

- Product: 33 Lock IntelliMortise Fire-Rated Hardware for Use in Fire-Resistance Rated Doors of the Following Models:
  - 1. 33 Lock IntelliMortise Silver IM-ANSI-SIL-NFP H85A
  - 2. 33 Lock IntelliMortise with Fingerprint Silver IM-ANSI-SIL-FP H85B
  - 3. 33 Lock IntelliMortise Silver Push Button IM-ANSI-SIL-PB-NFP
  - 4. 33 Lock IntelliMortise Silver Push Button with Fingerprint IM-ANSI-SIL-PB-FP

Products noted are available in black and silver finish.

Markings: See <u>FD001 - Fire Door Labeling requirements</u>

Models:

Product Name	Approved Door Types <sup>1</sup>	Pressure Type	Maximum Fire-resistance Rating
IntelliMortise	Wood, Wood Composite	Positive or Neutral	≤ 20 Minutes

1. Fire-resistance rated door certification is outside the scope of this listing and is to be provided an independent third-party product certification agency accredited to ISO 17065.

Notes: The listing noted pertains to above noted products listed intended for use with door assemblies used in fire-resistance rated applications. Where openings have additional criteria beyond the scope of fire-resistance rating, the Authority Having Jurisdiction (AHJ) should be consulted for approval.

Product is to be installed in accordance with the manufacturer's installation instructions.

Refer to the <u>FD002 - Fire Door Guidelines</u> for general guidelines of fire door assemblies.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 416.550.9280 WEBSITE: WWW.QAI.ORG

regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.