



ELECTRICAL LISTING PROGRAM

Customer: Analytic Systems Ware (1993) Ltd.
 Class: Power Conversion equipment
 Location: Delta, BC
 Listing No. E10806
 Report No. E10806-2307
 Project No. E10806-2307
 Effective Date: February 28, 2024
 Last Revised N/A
 Date:
 Expires: N/A

Standards: CSA C22.2 No. 107.1 – Power conversion equipment
 CSA C22.2 No. 107.2 – Battery Chargers

Product: Inverter – Charger

Markings: Products are marked in a permanent manner where it is readily visible after following installation with the:

- a) Manufacturer’s name or trademark
- b) Model designation
- c) Month and year of manufacture
- d) Product ratings: voltage, frequency, watts
- e) QAI file Number: E10806
- f) The wording ‘Conforms to CSA C22.2 No. 107.1 and CSA C22.2 No. 107.2’
- g) Warning markings as required by the standards in English and French>
- h) QAI logo shown here:



Models / Ratings:

Model	Rating	Description	Environmental Locations
IPSiC6105MY-28-120GDLS	120V/240V, 60Hz, 1Ph, 3.2KW / 28VDC, 6KW	6kW Inverter – Charger	Indoor

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.