

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419 WWW.QAL.ORG

# FIRE DOOR LISTING PROGRAM

Customer: Masonite Architectural Class: Fire Door Frames Location: Marshfield, WI Website: www.masonitearchitectural.com

Listing No. F487 Project No. F487-2 Edition 1

Effective Date: May 7, 2024 Last Revised: May 7, 2024

Standards:	CAN/ULC-S104	CAN/ULC-S104
	UL 10(b)	UL 10(b)
	UL 10(c)	UL 10(c)
	NFPA 252	NFPA 252

## Product: 90-minute Fire-Resistance Rated Frames

Label: See FD001 - Fire Door Labeling requirements

Models / 90-MINUTE COMPOSITE FIRE-RESISTANCE RATED CATEGORY C Ratings: FRAMES:

# MAXIMUM FRAME SIZES:

**Composite Frame Leg** 

Swing Type	Maximum Dimensions		
Swing Type:	Width:	Length:	
Single Swing	4'0" (1219 mm)	8'0" (2438 mm)	
Pairs	8'0" (2438 mm)	8'0" (2438 mm)	

Minimum Frame Leg Width:4Maximum Frame Leg Width:EMinimum Frame Leg Thickness:3Minimum Stop Height:5Minimum Stop Width:1

4-1/2" Equivalent to wall thickness 3/4" 5/8" 1-1/4"

# LIMITATIONS:

## Hinges:

- Butt hinges
- Continuous hinges.
- Pivot hinges.

All hinges and applicable hardware must be fire rated for use in openings at or above the fire rating of the frame system being installed. All hinges must be installed as per NFPA 80. Minimum leg thickness is 2 inches, and maximum pocket dimensions are 1-1/8 inch width x 2-7/16 inch height x 1-21/32 inch depth.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 416.550.9280 SEATTLE, WA 425.512.8419 WEBSITE: WWW.QAI.ORG

## Closers:

- Surface mounted permitted.
- Concealed permitted in neutral pressure (UL 10(b) / CAN/ULC S104) applications only.
- Notes: Refer to QAI evaluation report F424-2 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the <u>QAI FD002</u> - Fire Door Guidelines for general guidelines of fire door <u>assemblies</u>

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.

\*\*\*