



BUILDING PRODUCTS LISTING PROGRAM

Customer: Ilkorn Industries
Class: Housewrap
Location: Seattle, WA
Website: www.rollon.us

Listing No. B1148-1

Effective Date: October 16, 2024
Last Revised Date: October 16, 2024
Expires: <N/A>

Standards: ASTM E2556-10 *Standard Specification for Vapor Permeable Flexible Sheet Water-Resistive Barriers Intended for Mechanical Attachment*
ASTM E2178-21 *Standard Test Method for Air Permeance of Building Materials*
ASTM E84-23a *Standard Method of Test for Surface Burning Characteristics of Building Materials*

Product:	Model	Width	Length	Weight
	ROLLON Building Wrap	59-inches	102-feet	185 g/m ²

Markings: Listed products are identified with a label bearing the following information:

- Product Identification
- Company name, logo, address
- Product name
- QAI file number: B1148-1
- Information for traceability
- Roll length and width
- QAI logo shown here:





Ratings:

Product	Test Method	Classification/Rating
ROLLON Building Wrap	ASTM E2556	Type II
	ASTM E2178	Air Permeance < 0.02 L/(s*m ²)
	ASTM E84	Class A

Notes: This product must be installed in accordance with the code enforced by the authority having jurisdiction. Final acceptance of the product in the final installation is subject to inspection by the authority having jurisdiction.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
