

FIRE DOOR LISTING PROGRAM

Customer: JMD GLOBAL LLC.
 Class: Fire Doors
 Location: Deerfield Beach, FL
 Website: <https://jmdglobal.us/>

Listing No. F494-1-1- 90
 Project No. F494 Edition 1

Effective Date: September 27, 2024
 Last Revised Date: September 27, 2024

Standards: CAN/ULC S104 *Standard Method for Fire Tests of Door Assemblies.*
 UL 10B *Fire Tests of Doors Assemblies.*
 UL 10C *Fire Tests of Doors Assemblies.*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies.*

Product: 90-minute Fire-Resistance Rated Category A and Category B Doors

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: **Minimum 44 mm (1-3/4") Thickness**

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	(35-3/4") 908.05 mm	(95-1/4") 2419.35 mm	Flush	Single Point Mortise Lock

Category B doors require use of a minimum 90-minute rated Category G gasket approved for use with composite wood type doors when used in positive pressure applications.



Limitations:

Latch Sets (Listed and labeled for door type and rating)

- Mortised.
- Cylindrical.

Hinges (Listed and labeled for door type and rating)

- Minimum 4 ½" x 4" steel butt ball bearing hinges.

Hardware (Listed and labeled for door type and rating)

- Surface mounted only.

Louvers

- Not permitted

Viewers (Listed and labeled for rated opening)

- Not permitted

Glass Lights

- Not permitted

Electric Raceway

- Not permitted

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
