



BUILDING PRODUCT LISTING PROGRAM

Customer: DeckRite LLC
Class: Polyvinyl-Chloride Roofing
Location: North Little Rock, AR
Website: www.deckrite.com

Listing No. B1156
Project No. B1156, Edition 1

Effective Date: February 14, 2025
Last Revised: February 14, 2025
Expires: N/A

Standards: ASTM E108-20 "Standard Test Methods for Fire Tests of Roof Covering"
CAN/ULC S107-19 "Standard Methods of Fire Tests of Roof Coverings"
CAN/CGSB 37.54-95 "Polyvinyl Chloride Roofing and Waterproofing Membrane"

Product: DeckRite 60 mil externally reinforced nonwoven PVC
DeckRite 60 mil internally reinforced nonwoven PVC

Markings: Each roll of DeckRite 60 mil external reinforced and internally reinforced are marked with a permanent label containing the following information:

- a) Manufacturer's name or trademark
- b) Product name or product number
- c) Month and year of manufacture
- d) QAI logo with 'c' and 'us' indicators
- e) CGSB Type
- f) QAI file Number: B1156
- g) QAI logo shown here:



Models / Ratings:

Model	Nominal thickness	Surface	Roll Width(s)
DeckRite 60 mil externally reinforced	60 mils (1.5 mm)	Embossed	72-inches or 102-inches
DeckRite 60 mil internally reinforced	60 mils (1.5 mm)	Embossed	68-inches or 72-inches



Results:

Standard	Details	Rating
CAN/CGSB 37.54	DeckRite 60 mil externally reinforced	Type 3, Class B
	DeckRite 60 mil internally reinforced	Type 4, Class B

ASTM E108 / CAN/ULC S107: Decking Assembly Details

Rating:	Class A
Deck Slope Maximum:	1/4 : 12
Deck Sheathing:	Non-combustible sheathing defined and installed in accordance with the applicable code.
Approved Membrane(s):	DeckRite 60 mil internally reinforced (1.5 mm) adhered to the non-combustible substrate with 0280 all season contact adhesive (solvent-based) applied per DeckRite installation instructions at a rate of 1.47 m ² /L (60 ft ² /gallon) coverage.
	or
	DeckRite 60 mil externally reinforced (1.5 mm) adhered to the non-combustible substrate with 0280 all season contact adhesive (solvent-based) applied per DeckRite installation instructions at a rate of 1.47 m ² /L (60 ft ² /gallon) coverage.

Rating:	Class C
Deck Slope Maximum:	1/4 : 12
Deck Sheathing:	Minimum 12 mm (15/32") AC Exterior grade plywood. All deck joints are covered evenly with Mapei Planiprep SC Seam patch at a minimum thickness of 3 mm (1/8") prior to the membrane application.
Approved Membrane(s):	DeckRite 60 mil internally reinforced (1.5 mm) adhered to the non-combustible substrate with 0280 all season contact adhesive (solvent-based) applied per DeckRite installation instructions at a rate of 1.47 m ² /L (60 ft ² /gallon) coverage.
	Or
	DeckRite 60 mil externally reinforced (1.5 mm) adhered to the non-combustible substrate with 0280 all season contact adhesive (solvent-based) applied per DeckRite installation instructions at a rate of 1.47 m ² /L (60 ft ² /gallon) coverage.

Products must be installed with the manufacturer's published installation instructions and in accordance with the building codes recognized by the authority having jurisdiction.

Listed manufacturers are subject to on-going inspections by QAI to ensure that the products outlined above remains as it is listed.



Notes:

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
