

VANCOUVER, BC: LOS ANGELES, CA: TORONTO, ON: TULSA, OK: MIAMI. FL: WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 905.605.5444 ph. 918.437.8333 ph. | 305.885.3328 ph. | 305.885.3329 fx.

WWW.QAI.ORG

909.483.0336 fx. 918.437.8487 fx.

## FIRE DOOR LISTING PROGRAM

**Customer:** Custom Elevator Interiors

Class: Fire Doors Location: Jupiter, Florida

Website: https://customelevatorinteriors.com/

Listing No. F501

Project No. F501 Edition 1

Effective Date: March 11, 2025 Last Revised March 11, 2025

Date:

**Standards:** UL 10B (2020) Fire Tests of Door Assemblies.

> Standard Method for Fire Tests of Door Assemblies. CAN/ULC-S104 (2020)

Product: • 90-Minute Fire-Resistance Rated Center Parting Elevator Door Assembly.

90-Minute Fire-Resistance Rated 2-Speed Elevator Door Assembly.

90-Minute Fire-Resistance Rated Single Speed Elevator Door Assembly.

Models:

PRODUCT	MAXIMUM WIDTH in (mm)	MAXIMUM HEIGHT in (mm)	FIRE RATING ACHIEVED MINUTES
Frame	46 (1168)	86 (2184)	
Center Parting Elevator Door Assembly	21.75 (552)		
2-Speed Elevator Door Assembly	Largest Leaf 21.75 (552)	84.5 (2416)	90
Single Speed Elevator Door Assembly	48 (1219) Leaf Must Exceed Opening Size		

- Rollers: Component must be a GAL Type "A" sheave with top safety retainer and convex steel wheel with a nylon coating along the contact surface, or equivalent.
- Track: Component must be a GAL MONTX track/operator or equivalent.

**Markings:** Each product of Custom Elevator Interior is ink stamped with the following information:

- QAI Logo with "c" and "us" indicators.
- Manufacturer's name or trademark.
- Country of manufacture.
- QAI file number (F501-1).
- Traceability information.



VANCOUVER, BC: LOS ANGELES, CA: TORONTO, ON: TULSA, OK: MIAMI. FL: WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 905.605.5444 ph. 918.437.8333 ph. | 305.885.3328 ph. | 305.885.3329 fx.

WWW.QAI.ORG

909.483.0336 fx. 918.437.8487 fx.

See FD001 - Fire Door Labeling requirements

Notes: Refer to QAI evaluation report F501-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.

\*\*\*