



## **BUILDING PRODUCTS LISTING PROGRAM**

**Customer:** Cool Master Refrigeration Inc.

**Class:** Insulated Metal Panels

**Location:** Concord, Ontario Canada

**Website:** <https://www.coolmaster.ca>

**Listing No.** B1158

**Project No.** B1158-1 Edition 1

**Effective Date:** May 2, 2025

**Last Revised Date:** May 2, 2025

**Expires:** N/A

**Standards:** ASTM C518-17

*"Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus".*

**Product:** Cool Master Insulated Metal Panels (IMP) for walk-in coolers and freezers of the following types:

- Cool Master Continuous Panel
- Cool Master Camlock Panel

**Markings:** Each panel is marked with a permanent label containing the following information:

- a) Manufacturer's name or trademark
- b) Product type
- c) Production date
- d) Panel thickness requirements
- e) QAI file number: B1158
- f) QAI logo with 'c' identifier



:



**Models/Rating:** Cool Master Continuous and Camlock IMPs have the following thermal resistivity and minimum thickness required for compliance with National Resources Canada (NRCan) Energy Efficiency Regulation requirements when evaluated per ASTM C518 for applications noted.

Model	Application	Thermal Resistivity $m^2K/W$ ( $hr \cdot ft^2 \cdot ^\circ F / BTU \cdot in$ )	Minimum Panel Size	
			Thickness  mm (inches)	Thermal Resistance  $m^2 \cdot K/W$ ( $hr \cdot ft^2 \cdot ^\circ F / BTU$ )
Continuous Panel	Cooler 12.8°C (20°F)	53.11 (7.66)	89 (3.5)	4.72 (26.81)
	Freezer -6.7°C (20°F)	63.30 (9.13)	95 (3.75)	6.04 (34.24)
Camlock Panel	Cooler 12.8°C (20°F)	51.49 (7.43)	89 (3.5)	4.59 (26.01)
	Freezer -6.7°C (20°F)	58.58 (8.45)	102 (4.0)	5.95 (33.80)

Note 1: Evaluation was conducted in accordance with 10 CFR-2017, Part 431, Subpart R, Appendix B

**Notes:** Products must be installed with the manufacturer's published installation instructions and in accordance with the building codes recognized by the authority having jurisdiction.

Listed manufacturers are subject to on-going inspections by QAI to ensure that the products outlined above remains as it is listed.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*