



## FIRE DOORS LISTING PROGRAM

**Customer:** Williams Brothers Corporation of America  
**Class:** Fire Doors  
**Location:** Front Royal, Virginia, USA  
**Website:** <https://www.wbdoors.com>

**Listing No.** F500-1  
**Project No.** F500-1, Edition 1  
**Effective Date:** March 31, 2025  
**Last Revised:** March 31, 2025  
**Expires:** N/A

**Standards:** UL 10B (2020) *"Standard for Fire Tests of Door Assemblies".*  
CAN/ULC S104-15 *"Standard Method for Fire Tests of Door Assemblies."*  
ASTM E119-24 *"Standard Test Methods for Fire Tests of Building Construction and Materials."*  
CAN/ULC S101-14 *"Standard for Fire Tests of Door Assemblies".*

**Product:** Williams Brothers Fire-Resistance Rated Access Doors

**Labels** See [FD001 - Fire Door Labeling requirements](#)

**Models/Rating:** The following outlines Williams Brothers Fire-Resistance Rated Access Door performance determined in accordance with the noted standards. The ratings outlined in the tables below are achieved in assemblies that are described.

Williams Brothers FR 800 Insulated Steel Vertical Access Door and Frame evaluated to CAN/ULC S104 and UL 10B:

Model Name	Fire-Resistance Rating	Maximum Size	Frame	Door
FR 800 (Vertical)	90-Minutes	48 in. x 48 in. (1219 mm x 1219 mm)	16-Gauge Steel 2-5/8 in. (67 mm) Depth Frame	18-Gauge Steel 2 in. (51 mm) Depth Access Door



Williams Brothers FR 800 Insulated Steel Horizontal Access Door and Frame evaluated to CAN/ULC S101 and ASTM E119 for use in load-bearing fire resistance rated floor/ceiling assemblies:

Component	Description	
Assembly	Type:	Wood joist, gypsum and plywood.
	Fire-Resistance Rating:	60-Minutes
Access Door	Manufacturer:	Williams Brothers Corporation of America.
	Model:	FR 800 (Horizontal).
	Frame:	16-Gauge Steel 2-5/8 in. (67 mm) Depth.
	Door:	18-Gauge Steel 2 in. (51 mm) Depth
	Maximum Size:	36 in. x 36 in. (914 mm x 914 mm).
Framing	Type:	Nominal 2 in. x 8 in. (38 mm x 184 mm) dimensional wood joists, minimum specific gravity (SG) of 0.42, spaced 24 in. (610 mm) OC.
Gypsum Board	Type:	Type X gypsum board complying with ASTM C1396 and listed by a recognized agency.
	Joints:	Joints in gypsum board to be taped and mudded in accordance with industry standards.
Ceiling	Type:	Two layers of 1/2 in. (12.5 mm) Type X gypsum board.
	Fasteners:	Gypsum board is to be fastened to joists with #6 x 1-1/4 in. (32 mm) self-drilling drywall screws spaced at 8 in. (204 mm) on center.
Sub-Floor	Type:	One layer of 3/4 in. (20 mm) plywood attached in accordance with applicable code.
Opening	Type:	One layer of 5/8 in. (16 mm) Type X gypsum board around the perimeter of the opening.
	Fasteners:	Gypsum Board fastened to wood framing with #6 x 1-1/4 in. (32 mm) self-drilling drywall screws spaced at 8 in. (204 mm) on center.
Installation	Description:	Inside edge of framing around the opening fully covered with 5/8 in. (16 mm) Type X gypsum board. The door frame is screwed into the wood stud framing of the wall through mounting holes using #10 x 2 in. (51 mm) wood screws.



Williams Brothers DW 405 Phantom Horizontal Access Door and Frame evaluated to CAN/ULC S101 and ASTM E119 for use in use in load-bearing fire resistance rated floor/ceiling assemblies:

Component	Description	
Assembly Type	Type:	Steel joist, gypsum board ceiling and plywood flooring.
	Fire-Resistance Rating:	45-Minutes.
Access Door	Manufacturer:	Williams Brothers Corporation of America.
	Model:	DW 405 Phantom (Horizontal).
	Frame:	Type X gypsum.
	Door:	Type X gypsum.
	Maximum Size:	22 in. x 30 in. (559 mm x 762 mm)
Framing	Type:	3-5/8 in. x 1-1/4 in. (92 mm x 32 mm) steel joist support framing for the door and gypsum board spaced 24 in. (610 mm) OC.
Gypsum Board	Type:	Type X gypsum board complying with ASTM C1396 and listed by a recognized agency.
	Joints:	Joints in gypsum board to be taped/mudded in accordance with industry standards
Ceiling	Type:	One layer of 5/8 in. (16 mm) Type X gypsum board.
	Fasteners:	Gypsum board is to be fastened to joists with #6 x 1-1/4 in. (32 mm) self-drilling drywall screws spaced at 8 in. (204 mm) on center.
Sub-Floor	Type:	One layer of 3/4 in. (20 mm) plywood attached in accordance with applicable code.
Installation	Description:	Frame mounted to the steel framing with #6 x 1-1/4 in. (32 mm) self-drilling drywall screws spaced every 3 in. (76 mm). The door is manually placed on the frame edges to ensure uniform bearing coverage with no gaps between the door and frame into the floor / ceiling cavity space

Notes:

- Refer to QAI evaluation reports F500 and the applicable test reports for test assembly configurations used for fire endurance testing.
- Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)
- Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).
- Product is to be installed in accordance with the manufacturer's published installation instructions by qualified personnel.



The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*