



WINDOWS & DOORS LISTING PROGRAM

Customer: Base Windows Ltd.
Class: Fenestration Products – Energy and Physical Performance
Location: Concord, Ontario
Website: www.basewindows.com

Listing No. W602-1
Project No. W602-1 ED1
Effective Date: November 26, 2024
Last Revised Date: November 26, 2024
Expires: N/A

Standards: CSA A440.2-22 “Fenestration Energy Performance”
AAMA/WDMA/CSA 101/I.S.2/A440-17 “North American Fenestration Standard / Specification for windows, doors, and skylights (NAFS)”
CSA A440S1-19 “Canadian Supplement to NAFS 2017”

Product: Vinyl Windows

Markings: Products are marked with the following content in a permanent manner where it is readily visible after installation:

- a) Manufacturer’s name, Trademark or other recognized symbol or identification.
- b) QAI file Number: W602
- c) QAI logo shown here:



- d) “Evaluation for energy performance in accordance with CSA A440.2” and “Evaluation for physical performance in accordance with AAMA/WDMA/CSA 101/I.S.2/A440 and CSA A440S1”
- e) “Évalué pour la performance d’énergie en accord à la norme CSA A440.2” and “Évalué pour la performance de physique en accord à la norme AAMA/WDMA/CSA 101/I.S.2/A440 et CSA A440S1”

**Models / NAFS Performance Ratings:**

Product Series	Primary Designator	Positive Design Pressure	Negative Design Pressure	Water Penetration Test Pressure	Canadian Air Leakage Test Rating
2000 Series Slider Basement Window	Class R – PG25: Size tested 1194 x 895 mm (47.0 x 35.2 in) – Type BW	1200 Pa	-1200 Pa	150 Pa	A2 Level

Models / Energy Performance Ratings:**2000 Series Slider Basement Window**

Glass / Grille Option #	Model Code	U-Factor (W/m ² K)	Product SHGC	Energy Rating
G01	BASE-SS-3,CL-3,SG400(3)-12AR90IT	1.82	0.54	30

Notes:

- Products are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing.
- Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.
- The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.
- No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.
- Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.