

FIRE DOOR LISTING PROGRAM

Customer: A&J Sheet Metal Inc.
 Class: Fire Door
 Location: Jupiter, Florida
 Website: <https://ajsheetmetals.com/>

Listing No. F509-1
 Project No. F509-1 Edition 1

Effective Date: June 18, 2026
 Last Revised Date: N/A

Standards: CAN/ULC S104 (2015) *Standard Method for Fire Tests of Door Assemblies.*
 UL 10B (2024) *Fire Tests of Doors Assemblies.*

Product: 1) AJ-CO – Center Parting Elevator Door Assembly
 2) AJ-2SSS – 2-Speed Elevator Door Assembly
 3) AJ-SSSS – Single Speed Elevator Door Assembly

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: **90-MINUTE FIRE RATED ELEVATOR DOOR ASSEMBLIES**

Product(s)	Maximum Dimensions		Fire Rating (min)
	Width, in. (mm)	Height, in. (mm)	
Frame Opening	42 (1067)	84 (2134)	90
Center Parting Elevator Door Panel (AJ-CO)	21.75 (552)	84.5 (2146)	
2-Speed Elevator Door Panel (AJ-2SSS)	21.75 (552)		
Single Speed Elevator Door Panel (AJ-SSSS)	42.5 (1080)		

Limitations:

- Hardware: Door operating unit and associated electrical hardware shall be fire rated or listed for use in fire-rated assemblies by an approved agency.
- Rollers: Component must be a GAL Type “A” sheave with top safety retainer and steel wheel with a nylon coating along the contact surface, or equivalent.
- Track: Component must be a GAL MONTX track/operator or equivalent.
- Door Gibs: Stainless steel or equivalent.

Markings: Each product of A&J Sheet Metal Inc. is ink stamped with the following information:

- QAI Logo with “c” and “us” indicators.
- Manufacturer’s name or trademark.
- Country of manufacture.
- QAI file number (F509-1).
- Traceability information.

See [FD001 - Fire Door Labeling requirements](#)

Notes: Refer to QAI evaluation report F509-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
