QAI LABORATORIES
CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON 905.605.5444
SEATTLE, WA 425.512.8419
WEBSITE: WWW.QAI.ORG

PLUMBING LISTING PROGRAM

Customer: UPONOR, INC.
Class: Plumbing – Plastic Piping
Location: Virsbo, Sweden
Website: www.uponor-usa.com

Listing No. P321-5
Project No. P321-5 Edition 1

Effective Date: November 18, 2026
Last Revised Date: N/A

Standards: CAN/ULC-S102.2-18 "*Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies*".

Product: Uponor PEX Tubing - CleanPEX

Markings: All PEX tubing shall be permanently marked with the following content applied to an area that is readily visible after installation:

a) Manufacturers name or recognized trademark
b) Model name
c) Nominal Size
d) Date of manufacture
e) QAI file number: P321-5
f) CAN/ULC-S102.2
g) Flame Spread Index ≤ 25 and Smoke Developed Index ≤ 50
h) QAI logo shown here:



QAI LABORATORIES
CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON 905.605.5444
SEATTLE, WA 425.512.8419
WEBSITE: WWW.QAI.ORG

Models / Ratings: **The following outlines the performance of Uponor PEX Tubing, CleanPEX, determined in accordance with the noted standards.**

Model(s)	Dimensions	Limitations	Flame Spread Index	Smoke Developed Index
CleanPEX	20 mm 25 mm 32 mm	Maximum nominal pipe diameter: 32 mm Pipe shall be water-filled in the field. No minimum spacing required between adjacent runs of this pipe assembly.	≤ 25	≤ 50

Notes: Products must be installed with the manufacturer's published installation instructions and in accordance with the building codes recognized by the authority having jurisdiction.

Listed manufacturers are subject to on-going inspections by QAI to ensure that the products outlined above remains as it is listed.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.

***